

KING AMERICA FINISHING, INC.
 HWY 17
 DOVER, GA 30424

BEGINNING 03/01/14
 DATE MO/DA/YR
 END 03/31/14

LOCATION CODE	001		001	001	001	001	001	001	001	001	001	001	001	001	001	001	001
PARAMETER NAME & UNITS	FLOW D. AVG MGD		BOD lbs/day	BOD mg/l	COD lbs/day	COD mg/l	TSS lbs/day	TSS mg/l	SULFIDES lbs/day	SULFIDES mg/l	TDS mg/l	TOTAL PHENOLS lbs/day	TOTAL PHENOLS mg/l	TOTAL CHROMIUM lbs/day	TOTAL CHROMIUM mg/l	TOTAL AMMONIA lbs/day	TOTAL AMMONIA mg/l
TYPE OF SAMPLE	CONT.		COMP.	COMP.	COMP.	COMP.	COMP.	COMP.	GRAB	GRAB	COMP.	GRAB	GRAB	COMP.	COMP.	COMP.	COMP.
FREQUENCY OF ANALYSIS	DAILY		FIVE WEEK	FIVE WEEK	FIVE WEEK	FIVE WEEK	FIVE WEEK	FIVE WEEK	DAILY	DAILY	FIVE WEEK	ONE WEEK	ONE WEEK	ONE WEEK	ONE WEEK	DAILY	DAILY
LIMITS	AVG 3.1		AVG 776 MAX 1552	AVG 30 MAX 60	AVG 5500 MAX 11000	REPORT	AVG 2140 MAX 4280	REPORT	AVG 24 MAX 48	AVG 1.5 MAX 3.0	AVG 2500 MAX 3800	AVG 5.0 MAX 15	REPORT	AVG 12 MAX 24	AVG 1.2 MAX 2.4	AVG 260 MAX 520	AVG 7 MAX 13
DATE																	
03/01/14	2.08								ND17	ND1.0						31.4	1.81
03/02/14	1.77								ND15	ND1.0						27.3	1.85
03/03/14	1.72		181	12.60	2,410	168	265	19	ND14	ND1.0	2,300					27.1	1.89
03/04/14	1.67		277	19.90	2,242	161	327	24	ND14	ND1.0	2,430					13.9	1.00
03/05/14	1.36		253	22.30	2,030	179	281	25	ND11	ND1.0	2,310	1.2	0.11	ND1.1	ND0.10	23.0	2.03
03/06/14	1.40		220	18.80	2,288	196	251	22	ND12	ND1.0	2,310					24.1	2.06
03/07/14	1.53		226	17.70	2,629	206	325	26	ND13	ND1.0	2,230					13.9	1.09
03/08/14	1.49								ND12	ND1.0						12.8	1.03
03/09/14	1.43								ND12	ND1.0						11.3	0.95
03/10/14	1.40		295	25.30	2,032	174	598	51	ND12	ND1.0	2,110					12.5	1.07
03/11/14	1.56		332	25.50	2,641	203	299	23	ND13	ND1.0	2,220					22.8	1.75
03/12/14	1.61		375	27.90	2,887	215	423	32	ND13	ND1.0	2,340	ND1.3	ND0.10	ND1.3	ND0.10	27.4	2.04
03/13/14	1.66		521	37.60	3,295	238	401	29	ND14	ND1.0	2,390					17.0	1.23
03/14/14	1.68		678	48.40	3,881	277	862	62	ND14	ND1.0	2,560					47.4	3.38
03/15/14	1.80								ND15	ND1.0						47.1	3.14
03/16/14	1.79								ND15	ND1.0						36.3	2.43
03/17/14	1.74		527	36.30	3,280	226	428	30	ND15	ND1.0	2,180					25.1	1.73
03/18/14	1.66		266	19.20	2,464	178	270	20	ND14	ND1.0	2,110					15.6	1.13
03/19/14	1.67		334	24.00	2,591	186	467	34	ND14	ND1.0	2,140	ND1.4	ND0.10	ND1.4	ND0.10	15.9	1.14
03/20/14	1.72		349	24.30	2,424	169	442	31	ND14	ND1.0	2,060					23.2	1.62
03/21/14	1.66		336	24.30	2,630	190	395	29	ND14	ND1.0	2,000					18.4	1.33
03/22/14	1.90								ND16	ND1.0						27.4	1.73
03/23/14	1.42								ND12	ND1.0						18.7	1.58
03/24/14	1.36		373	32.90	2,847	251	902	80	ND11	ND1.0	2,390					21.9	1.93
03/25/14	1.56		207	15.90	2,407	185	117	9	ND13	ND1.0	2,390					39.0	3.00
03/26/14	1.53		240	18.80	2,463	193	223	18	ND13	ND1.0	2,450	ND1.3	ND0.10	ND1.3	ND0.10	114.6	8.98
03/27/14	1.67		442	31.70	2,911	209	334	24	ND14	ND1.0	2,610					94.7	6.80
03/28/14	1.42		262	22.10	2,333	197	156	13	ND12	ND1.0	2,530					12.3	1.04
03/29/14	1.21								ND10	ND1.0						29.9	2.96
03/30/14	1.35								ND11	ND1.0						28.1	2.50
03/31/14	1.35		150	13.30	1,937	172	355	32	ND11.26	ND1.0	2,300					25.6	2.27
# SAMPLES	31		21	21	21	21	21	21	31	31	21	4	4	4	4	31	31
AVG. VALUE	1.586		326	25	2601	199	387	30	13.23	1.00	2302.86	1.315	0.103	1.286	0.100	29.22	2.21
MAX. VALUE	2.080		678	48	3881	277	902	80	17.35	1.00	2610.00	1.393	0.110	1.393	0.100	114.59	8.98
MIN. VALUE	1.210		150	13	1937	161	117	9	10.09	1.00	2000.00	1.248	0.100	1.134	0.100	11.33	0.95
# MAX EXCD.	0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

NAME OF PRINCIPAL EXECUTIVE OFFICER
Beasley Michael A.
 LAST FIRST MI

TITLE OF THE OFFICER
President/CEO
 TITLE

DATE
 04/17/14
 YR/MO/DA

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED
 IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND
 BELIEF SUCH INFORMATION IS TRUE, COMPLETE, AND ACCURATE.

KING AMERICA FINISHING, INC.
 HWY 17
 DOVER, GA 30424

BEGINNING 03/01/14
 DATE MO/DA/YR
 END 03/31/14

LOCATION CODE	001	001	001	001	001	001	001	001	001	001	001	001	001	001	001	001	001
PARAMETER NAME & UNITS	TKN mg/l	TOTAL NITROGEN mg/l	TOTAL PHOS. mg/l	ORTHO PHOS. mg/l	CONDUCT. HIGH umhos/cm	FORMALDEH mg/l	EFF COLOR ADMI SU	SODIUM mg/l	PEROXIDE mg/l	THPC mg/l	FECAL COLIFORM #/100 ml	ACUTE TOX. FLEA - LC50 %	CHRON. TOX. FLEA - NOEC %	ACUTE TOX. FATHEAD LC50 %	CHRON. TOX. FATHEAD NOEC %	DO LOW mg/l	DO mg/l
TYPE OF SAMPLE	COMP.	COMP.	COMP.	COMP.	CONT.	GRAB	GRAB	COMP.	GRAB	GRAB	GRAB	COMP.	COMP.	COMP.	COMP.	CONT.	GRAB
FREQUENCY OF ANALYSIS	ONE WEEK	ONE WEEK	THREE WEEK	THREE WEEK	DAILY	DAILY	ONE WEEK	DAILY	DAILY	TWO MONTH	ONE WEEK	TWO WEEK	ONE MONTH	ONCE QUARTER	ONCE QUARTER	DAILY	FIVE WEEK
LIMITS	REPORT	REPORT	REPORT	REPORT	REPORT	REPORT MAX 1.6	REPORT	REPORT	REPORT	REPORT	AVG 200 MAX 400	MIN >100	MIN 10	MIN >100	MIN 10	MIN 5.0	MIN 5.0
DATE																	
03/01/14					3,540	0.31		738	0.0			>100				8.40	8.49
03/02/14					3,540	0.22		746	0.0			>100				8.40	8.91
03/03/14			15.90	ND0.020	3,540	0.16		729	0.0			>100	80			7.80	8.21
03/04/14					3,600	0.43		756	0.5			>100				7.80	8.98
03/05/14	11.90	56.60	19.40	0.031	3,600	0.36	61	725	0.0		17	>100				9.00	10.02
03/06/14					3,600	0.61		622	0.0							9.00	9.39
03/07/14			25.30	0.022	3,480	0.38		705	0.5							9.00	9.37
03/08/14					3,360	0.26		671	1.0							8.40	9.03
03/09/14					3,240	0.16		678	0.5							8.40	8.71
03/10/14			16.00	0.054	3,240	0.13		674	0.0			>100		>100	50	7.20	9.63
03/11/14					3,360	0.21		671	0.0							7.80	8.73
03/12/14	13.70	55.60	17.50	0.830	3,540	0.22		727	0.0		17					6.60	8.40
03/13/14					3,720	0.52	79	710	0.0			>100				6.60	9.89
03/14/14			12.90	0.276	3,780	0.57		759	0.0							7.20	8.74
03/15/14					3,780	0.56		712	0.5							7.20	8.57
03/16/14					3,660	0.36		676	0.0							7.20	8.53
03/17/14			14.20	0.415	3,480	0.30		641	0.0			>100				6.60	7.98
03/18/14					3,300	0.41		624	0.0	ND12.00						6.60	8.97
03/19/14	14.20	63.00	10.10	0.144	3,120	0.21	64	662	0.5		10	>100				7.80	8.90
03/20/14					3,180	0.38		700	0.0							7.20	7.51
03/21/14			21.80	0.039	3,180	0.52		674	0.0							6.60	8.76
03/22/14					3,240	0.46		629	0.0							7.80	8.68
03/23/14					3,420	0.28		689	0.0							7.20	8.01
03/24/14			22.30	0.600	3,600	0.31		725	0.0	ND12.00		>100				6.60	9.02
03/25/14					3,660	0.24		690	0.0							7.80	8.75
03/26/14	20.30	63.90	18.80	0.020	3,780	0.29	64	730	0.0			>100				7.80	9.67
03/27/14					3,840	0.64		716	0.0							8.40	8.92
03/28/14			11.50	0.027	3,840	0.56		777	0.0		3					7.80	8.68
03/29/14					3,840	0.37		772	0.5							7.80	8.11
03/30/14					3,720	0.22		763	0.0							7.20	8.53
03/31/14			22.40	0.386	3,720	0.22		710	0.0			>100				7.80	8.76
# SAMPLES	4	4	13	13	31	31	4	31	31	2	4	12	1	1	1	31	31
AVG. VALUE	15.0	59.8	17.5	0.2	3532.3	0.35	67	703	0.13	12.00	10	100	80	100	50	7.6	8.8
MAX. VALUE	20.3	63.9	25.3	0.8	3840.0	0.64	79	777	1.00	12.00	17	100	80	100	50	9.0	10.0
MIN. VALUE	11.90	55.60	10.10	0.02	3120.00	0.13	61	622	0.00	12.00	3	100	80	100	50	6.60	7.51
# MAX EXCD.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

NAME OF PRINCIPAL EXECUTIVE OFFICER
Beasley Michael A.
 LAST FIRST MI

TITLE OF THE OFFICER
President/CEO
 TITLE

DATE
 04/17/14
 YR/MO/DA

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED
 IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND
 BELIEF SUCH INFORMATION IS TRUE, COMPLETE, AND ACCURATE.

KING AMERICA FINISHING, INC.
 HWY 17
 DOVER, GA 30424

BEGINNING 03/01/14
 DATE MO/DA/YR
 END 03/31/14

LOCATION CODE	001	001	001	001	001	001	PLANT	001	002	002	002	001/002		002	002	002	002
PARAMETER NAME & UNITS	pH HIGH SU	pH LOW SU	pH SU	TEMP. HIGH DEG. F	TEMP. LOW DEG. F	TEMP. DEG. F	SOLIDS REMOVED lbs/day	FLOW MGD	STREAM FLOW CFS	STREAM FLOW MGD	EFF / STREAM FLOW %	EFF/UP STR COLOR DIFF. ADMI SU		UPSTREAM COLOR ADMI SU	UP STREAM PH SU	UP STREAM TEMP. DEG. F	UP STREAM CONDUCT. umhos/cm
TYPE OF SAMPLE	CONT.	CONT.	GRAB	CONT.	CHART	GRAB	GRAB	CONT.	GAUGE	CAL.	CAL.	GRAB		GRAB	GRAB	GRAB	GRAB
FREQUENCY OF ANALYSIS	DAILY	DAILY	FIVE WEEK	DAILY	DAILY	FIVE WEEK	DAILY	DAILY	DAILY	DAILY	DAILY	ONE WEEK		ONE WEEK	ONCE MONTH	ONCE MONTH	ONCE MONTH
LIMITS	MIN 6.0 MAX 8.0	MIN 6.0 MAX 8.0	MIN 6.0 MAX 8.0	REPORT	REPORT	REPORT	REPORT	MAX 3.1	REPORT	REPORT	MAX 8	MAX 80		REPORT	REPORT	REPORT	REPORT
DATE																	
03/01/14	7.56	7.56	7.59	63	60	62.24	0	2.08	3,170	2,048.68	0						
03/02/14	7.70	7.56	7.16	66	63	63.68	0	1.77	2,990	1,932.35	0						
03/03/14	7.70	7.70	7.69	66	63	64.40	0	1.72	2,870	1,854.80	0						
03/04/14	7.84	7.70	7.68	69	63	62.78	0	1.67	2,870	1,854.80	0						
03/05/14	7.70	7.56	7.61	63	57	57.92	0	1.36	2,860	1,848.34	0	-12		73	6.240	50.32	45
03/06/14	7.70	7.42	7.53	60	57	59.36	0	1.40	2,630	1,699.70	0						
03/07/14	7.42	7.42	7.39	60	60	57.92	0	1.53	2,680	1,732.01	0						
03/08/14	7.56	7.42	7.54	60	60	59.54	0	1.49	2,800	1,809.56	0						
03/09/14	7.56	7.56	7.58	63	60	64.58	0	1.43	2,930	1,893.58	0						
03/10/14	7.70	7.56	7.54	66	63	65.66	0	1.40	3,010	1,945.28	0						
03/11/14	7.70	7.56	7.62	69	66	66.74	0	1.56	3,060	1,977.59	0						
03/12/14	7.56	7.42	7.60	72	66	68.90	0	1.61	3,130	2,022.83	0						
03/13/14	7.42	7.28	7.43	72	66	65.30	0	1.66	3,080	1,990.52	0	-10		89	6.350	57.36	62
03/14/14	7.42	7.28	7.35	66	60	58.82	0	1.68	3,000	1,938.82	0						
03/15/14	7.42	7.42	7.40	63	60	64.04	0	1.80	2,930	1,893.58	0						
03/16/14	7.42	7.28	7.49	69	63	67.82	0	1.79	2,940	1,900.04	0						
03/17/14	7.56	7.42	7.58	69	66	68.36	0	1.74	3,410	2,203.79	0						
03/18/14	7.56	7.56	7.56	69	63	61.16	0	1.66	3,990	2,578.63	0						
03/19/14	7.56	7.42	7.47	63	60	61.52	0	1.67	4,320	2,791.90	0	-46		110	5.540	52.84	48
03/20/14	7.42	7.28	7.41	66	63	64.94	0	1.72	4,300	2,778.97	0						
03/21/14	7.42	7.28	7.44	72	66	65.66	0	1.66	4,240	2,740.19	0						
03/22/14	7.42	7.42	7.54	69	69	67.46	0	1.90	4,100	2,649.72	0						
03/23/14	7.42	7.42	7.54	72	69	69.44	0	1.42	3,770	2,436.45	0						
03/24/14	7.70	7.42	7.72	72	66	66.38	0	1.36	3,500	2,261.95	0						
03/25/14	7.56	7.56	7.59	66	63	62.96	0	1.56	3,360	2,171.47	0						
03/26/14	7.56	7.56	7.44	66	63	59.18	0	1.53	3,370	2,177.94	0	-29		93	6.040	55.20	57
03/27/14	7.56	7.56	7.63	60	60	57.92	0	1.67	3,460	2,236.10	0						
03/28/14	7.56	7.56	7.47	66	60	64.04	0	1.42	3,450	2,229.64	0						
03/29/14	7.70	7.56	7.65	69	63	70.34	0	1.21	3,320	2,145.62	0						
03/30/14	7.56	7.56	7.58	72	69	66.92	0	1.35	3,120	2,016.37	0						
03/31/14	7.56	7.56	7.52	69	63	61.34	0	1.35	2,840	1,835.41	0						
# SAMPLES	31	31	31	31	31	31	31	31	31	31	31	4		4	4	4	4
AVG. VALUE	7.6	7.5	7.5	67	63	63.78	0	1.586	3274.19	2116.02	0.08	-24.25		91	6.0	53.93	53
MAX. VALUE	7.8	7.7	7.7	72	69	70.34	0	2.080	4320.00	2791.90	0.09	-10.00		110	6.4	57.36	62
MIN. VALUE	7.4	7.3	7.2	60	57	57.92	0	1.210	2630.00	1699.70	0.05	-46.00		73	5.5	50.32	45
# MAX EXCD.	0	0	0	0	0	0	0	0	0	0	0	0		0	0	0	0

NAME OF PRINCIPAL EXECUTIVE OFFICER
Beasley Michael A.
 LAST FIRST MI

TITLE OF THE OFFICER
President/CEO
 TITLE

DATE
04/17/14
 YR/MO/DA

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED
 IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND
 BELIEF SUCH INFORMATION IS TRUE, COMPLETE, AND ACCURATE.

KING AMERICA FINISHING, INC.
 HWY 17
 DOVER, GA 30424

BEGINNING 03/01/14
 DATE MO/DA/YR
 END 03/31/14

LOCATION CODE	002	002	002	002	002	002		002	002	002	002	002	002	002	002	002	002
PARAMETER NAME & UNITS	UP STREAM AMMONIA mg/l	UP STREAM FORMALDEH mg/l	UP STREAM SODIUM mg/l	UP STREAM SULFIDE mg/l	UP STREAM PEROXIDE mg/l	UP STREAM DO mg/l		DWNSTREAM COLOR ADMI SU	DWNSTREAM PH SU	DWNSTREAM TEMP. DEG. F	DWNSTREAM CONDUCT. umhos/cm	DWNSTREAM AMMONIA mg/l	DWNSTREAM FORMALDEH mg/l	DWNSTREAM SODIUM mg/l	DWNSTREAM SULFIDE mg/l	DWNSTREAM PEROXIDE mg/l	DWNSTREAM DO mg/l
TYPE OF SAMPLE	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB		GRAB	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB
FREQUENCY OF ANALYSIS	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH		ONE WEEK	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH	ONCE MONTH
LIMITS	REPORT	REPORT	REPORT	REPORT	REPORT	REPORT		REPORT	REPORT	REPORT	REPORT	REPORT	REPORT	REPORT	REPORT	REPORT	REPORT
DATE																	
03/01/14																	
03/02/14																	
03/03/14																	
03/04/14																	
03/05/14	ND0.200	ND0.05	ND5.00	ND1.00	0.00	9.53		86	6.250	50.34	46	ND0.200	ND0.05	ND5.00	ND1.00	0.0	9.56
03/06/14																	
03/07/14																	
03/08/14																	
03/09/14																	
03/10/14																	
03/11/14																	
03/12/14																	
03/13/14					0.00	8.04		99	6.370	57.36	62					0.0	8.02
03/14/14																	
03/15/14																	
03/16/14																	
03/17/14																	
03/18/14																	
03/19/14					0.00	8.36		110	5.600	52.86	49					0.0	8.56
03/20/14																	
03/21/14																	
03/22/14																	
03/23/14																	
03/24/14																	
03/25/14																	
03/26/14					0.00	7.69		92	6.250	55.18	64					0.0	7.98
03/27/14																	
03/28/14																	
03/29/14																	
03/30/14																	
03/31/14																	
# SAMPLES	1	1	1	1	4	4		4	4	4	4	1	1	1	1	4	4
AVG. VALUE	0.2	0.050	5	1.0	0.0	8.4		97	6.1	53.9	55	0.2	0.05	5	1.0	0.0	8.5
MAX. VALUE	0.2	0.050	5	1.0	0.0	9.5		110	6.4	57.4	64	0.2	0.05	5	1.0	0.0	9.6
MIN. VALUE	0.2	0.050	5	1.0	0.0	7.7		86	5.6	50.3	46	0.2	0.05	5	1.0	0.0	8.0
# MAX EXCD.	0	0	0	0	0	0		0	0	0	0	0	0	0	0	0	0

NAME OF PRINCIPAL EXECUTIVE OFFICER
Beasley Michael A.
 LAST FIRST MI

TITLE OF THE OFFICER
President/CEO
 TITLE

DATE
04/17/14
 YR/MO/DA

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED
 IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND
 BELIEF SUCH INFORMATION IS TRUE, COMPLETE, AND ACCURATE.

KING AMERICA FINISHING, INC.
 HWY 17
 DOVER, GA 30424

BEGINNING 03/01/14
 DATE MO/DA/YR
 END 03/31/14

LOCATION CODE	002	002		002		WELL	001									
PARAMETER NAME & UNITS	DN-STR ACUTE FLEA LC50 %	DN-STR CHRON FLEA NOEC %		DN-STR T. HARDNESS mg/l		MERCURY ng/L	MERCURY ng/L									
TYPE OF SAMPLE	GRAB	GRAB		GRAB		Grab	Grab									
FREQUENCY OF ANALYSIS	ONE MONTH	ONE MONTH		ONCE MONTH		ONCE MONTH	ONCE MONTH									
LIMITS	REPORT	REPORT		REPORT		REPORT	REPORT									
DATE																
03/01/14	>100															
03/02/14	>100															
03/03/14	>100	100														
03/04/14	>100															
03/05/14	>100			22.00		ND0.50	1.15									
03/06/14																
03/07/14																
03/08/14																
03/09/14																
03/10/14																
03/11/14																
03/12/14																
03/13/14																
03/14/14																
03/15/14																
03/16/14																
03/17/14																
03/18/14																
03/19/14																
03/20/14																
03/21/14																
03/22/14																
03/23/14																
03/24/14																
03/25/14																
03/26/14																
03/27/14																
03/28/14																
03/29/14																
03/30/14																
03/31/14																
# SAMPLES	5	1		1		1	1									
AVG. VALUE	100	100		22		1	1									
MAX. VALUE	100	100		22		1	1									
MIN. VALUE	100	100		22		1	1									
# MAX EXCD.	0	0		0		0	0									

NAME OF PRINCIPAL EXECUTIVE OFFICER
Beasley Michael A.
 LAST FIRST MI

TITLE OF THE OFFICER
President/CEO
 TITLE

DATE
04/17/14
 YR/MO/DA

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED
 IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND
 BELIEF SUCH INFORMATION IS TRUE, COMPLETE, AND ACCURATE.